DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6365DO0499
Registration Number
Registriernummer

Field of Application ***Anwendungsbereich***	products of water supply *Produkte der Wasserversorgung*
Owner of Certificate ***Zertifikatinhaber***	JCH A/S Karetmagervej 21, DK-7100 Vejle
Distributor ***Vertreiber***	JCH A/S Karetmagervej 21, DK-7100 Vejle
Product Category ***Produktart***	Valves for drinking water: standpipe backflow preventer BA accord. DIN EN 1717 (6365)
Product description ***Produktbezeichnung***	backflow preventer BA for standpipe
Model ***Modell***	Backflow preventer 4-AQUA-PRO
Test reports ***Prüfberichte***	Supplement test: 262561 from 19.02.2025 (DTI) Type testing: 130458-A from 09.12.2022 (DTI) Type testing: 130458-B from 30.01.2023 (DTI) Type testing: 915353 from 17.04.2020 (DTI)
Test basis ***Prüfgrundlagen***	DVGW W 570-1 (01.03.2013) DIN EN 12729 (01.02.2003)
Date of Expiry / File No. ***Ablaufdatum / Aktenzeichen***	30.01.2028 / 25-0927-WNR

70028-04-A-DE

02.12.2025 Bn A-1/2 i.A. W. Tl

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DAkkS Deutsche Akkreditierungsstelle D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type *Typ*	Technical Data *Technische Daten*	Remarks *Bemerkungen*
2490	Pressure rating: PN 10 Nominal diameter: DN 15 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 20 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 25 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 32 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 40 mm	
2490	Pressure rating: PN 10 Nominal diameter: DN 50 mm	

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

The hygienic safety of all materials that come into contact with drinking water has been proven.

DVGW CERT